

**Certificate Number:** AZ 69025394

Page: 0008



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV025394E

CONTINUATION SHEET 7

( Modification 1)

1. Update standard from AS/NZS 4777.2:2020 to AS/NZS 4777.2: 2020 + A1;

2. Change DC switch to Shanghai Liangxin Electrical Co.,Ltd. NDG3V-50, AZ 69025902

3. Change PV short circuit of S5-GC25K-AU, S5-GC30K-AU, S5-GC33K-AU, S5-GC36K-AU, S5-GC40K-AU, S5-GC40K-HV-AU, S5-GC50K-HV-AU from 4×50A to 4×40A.

Issue Date: 27/04/2022

Expiry Date: 03/09/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read "Grant Li".

Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)