

## CERTIFICATE OF SUITABILITY

Authorised marking: TUV025304E

CONTINUATION SHEET 9

(Modification 1)

1. Update standard from AS/NZS 4777.2:2020 to AS/NZS 4777.2: 2020 + A1;
2. Change DC switch to Shanghai Liangxin Electrical Co.,Ltd.  
NDG3V-50, AZ 69025902
3. Change PV short circuit current Isc of S5-GR3P5K-AU and S5-GR3P6K-AU from 50+25A to 40+20A,
4. Change PV short circuit current Isc of S5-GR3P8K-AU, S5-GR3P9K-AU, S5-GR3P10K-AU, S5-GR3P12K, S5-GR3P13K S5-GR3P15K, S5-GR3P17K, S5-GR3P20K from 2×50A to 2×40A

Issue Date: 27/04/2022  
Expiry Date: 23/07/2026

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*



Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)