

A P P R O V A L S ®

## Certificate of Suitability

## Certificate No.:

## SAA191574

Certificate Holder:

Ningbo Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang P.R. China

Class Description: Product Description: Brand Name: Model No.: Markings:

Standard:

Conditions:

**Certification Mark:** 

Date of Expiry:

**Date First Registered:** 

Non-Declared Grid-tied Inverter (Non-Isolated) Ginlong Solis-1P5K-4G Input: 600Vdc Max, MPP range 90-520Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 5000VA IP65, -25...60°C, Over Voltage category II (PV), III (Mains) Non-isolated IEC 62109-1 Ed 1.0 IEC 62109-2 Ed 1.0 AS/NZS 4777.2:2015 Nil

SAA191574 or RCM

20 June 2019 20 June 2024

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au





www.jas-anz.org/register