



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA191574

Date of Issue: 20 June 2019

Class Description: Non-Declared

Product Description: Grid-tied Inverter (Non-Isolated)

Additional Models	Trade Name	Rating
Mate-1P5K-4G-W	SOLTARO	Input: 600Vdc Max, MPP range 90-520Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 5000VA
Mate-1P4.6K-4G-W	SOLTARO	Input: 600Vdc Max, MPP range 90-520Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21.7A 4600VA
Mate-1P4K-4G-W	SOLTARO	Input: 600Vdc Max, MPP range 90-520Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 21A 4400VA
Mate-1P3.6K-4G-W	SOLTARO	Input: 600Vdc Max, MPP range 90-520Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 16A 4000VA
Mate-1P3K-4G-W	SOLTARO	Input: 600Vdc Max, MPP range 90-520Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 15.7A 3300VA
Mate-1P2.5K-4G-W	SOLTARO	Input: 550Vdc Max, MPP range 50-450Vdc, 2x11A Isc 2x17.2A Output: 230/240V~ 50Hz 13.3A 2800VA


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-06-19 191574/4