



Fair
Trading

File Ref: CS11080/2
Contact: Admin Clerk
Telephone: 02 9895 0722

JIANYONG LI
GINLONG TECHNOLOGIES CO., LTD.
C/- TUV SUD CERTIFICATION AND TESTING
(CHINA) CO., LTD. SHANGHAI BRANCH
3-13, No.151, Heng Tong Road
Shanghai, China 200070

Dear Sir/Madam

VARIATION TO CERTIFICATE OF SUITABILITY: CS11080N

Inverter

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

 17 March 2023

For Secretary, Department of Customer Service



Fair
Trading

Ref: CS11080/2

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11080N Particulars of Modification(s)

Model No. S6-GR1P7K2 being similar to Model No. Solis-1P8K-5G except for: -
Maximum Input DC current: 13.5+27A
Rated Continuous Output AC current: 33.5A
Rated Output Power: 7KW/7KVA
Maximum AC output active power: 7.7KW
Maximum AC Apparent Output Power: 7.7KVA
Ingress Protection: IP66

Model No. S6-GR1P8K2 being similar to Model No. Solis-1P8K-5G except for: -
Maximum Input DC current: 13.5+27A
Rated Continuous Output AC current: 36.4A
Rated Output Power: 8KW/8KVA
Maximum AC output active power: 8.8KW
Maximum Apparent Output Power: 8.8KVA
Ingress Protection: IP66

General Modification: For compliance with performance requirements refer to test report No. CN22RVXU001 dated 18/04/2022, 50309646 006 dated 07/11/2022, CQCTT-WT-2022-A0015 dated 20/04/2022 and CQCTT-WT-2022-A0118 dated 24/02/2023.

This certificate will expire on 29/04/2027

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

 17 March 2023

For Secretary, Department of Customer Service