

**Certificate Number:** AZ 69025902

Page: 0058



## CERTIFICATE OF APPROVAL

Authorised marking: TUV-025902-EA

CONTINUATION SHEET 57

(Modification 24)

Classified as:

Installed within power conditioning equipment (PCE), enclosed outdoor, suitable for installation exposed to sunlight as per AS/NZS 5033.

Switch arrangement: NDG3V-50/6/1/01/M/AS, 6 layers

Installed within Grid-connected PV Inverter

lthe Solar at 40°C: 25A, lthe Solar at 60°C: 25A

Brand: solis

Models: S6-GR3P5K03-NV-ND-AU, S6-GR3P6K03-NV-ND-AU,

S6-GR3P8K03-NV-ND-AU, S6-GR3P9K03-NV-ND-AU,

S6-GR3P9.9K03-NV-ND-AU, S6-GR3P10K03-NV-ND-AU

Size: 355mm×410mm×179mm (W x H x D)

Enclosure material: AL5052

Issue Date: 25/06/2024

Expiry Date: 29/03/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'John Wang'.

John Wang



www.jas-anz.org  
register