

CERTIFICATE OF CONFORMITY / APPROVAL

Authorised marking: TUV-028529-EA

CONTINUATION SHEET 29

(Modification 26)

Classified as:

D.4.5 (f): Enclosed outdoors, exposed to sunlight, mounted in aspecified PCE - for use in PCE enclosure, enclosed outdoor, suitable for installation exposed to sunlight as perAS/NZS 5033.

Switch arrangement: 3 switches arrangement,

2 switches NDG3V-50/4/1/01/M/AS, 4 layers and 1 switchNDG3V-50/2/1/01/M/AS,

2 layers; "+" and "-" in series for 1 string, total 5 strings

Installed within Grid-connected PV Inverter

Brand: Solis

Models: S5-GC50K

Size: 691mm×578mm×338mm (W x H x D)

Enclosure material: AL5052, Wall thickness: 2mm, Volume: 0,13m³

Input: DC-PV2: Ue=1100VDC, Ie=32A

Ui=1500V, Uimp=8kV, Iu=32A, Ithe=32A,

Ithe Solar at 40°C=32A, Ithe Solar at 60°C=12A

Issue Date: 28-10-2025

Expiry Date: 16-05-2030

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



Rafeeqe Mohamed

© TÜV, TÜEV and TÜV are registered trademarks. Utilisation and application requires prior approval.

